



CITY OF LODI

COUNCIL COMMUNICATION

AGENDA TITLE: Specifications and Advertisement for Bids for Industrial Substation 12KV Electrical Bus Conductor

MEETING DATE: January 15. 1992

PREPARED BY: Electric Utility Director

RECOMMENDED ACTION: That the City Council approve the specifications and authorize advertisement for bids for the purchase of 1,600 feet of 3", and 1,000 feet of 1.5" aluminum bus conductor for use in construction of the 12kv distribution structure at the Industrial Substation.

BACKGROUND INFORMATION: The electrical bus conductor will be used in the construction of the 12kv distribution structure at the Industrial Substation. This structure is a major component of the equipment being installed at the site. This system expansion will provide additional electrical capacity, primarily for industrial and commercial customers in the eastern part of the City.

FUNDING: The estimated cost of this purchase is \$9,000, with funding available in the Electric Utility Department's 1991-92 fiscal year budget.


Henry J. Rice, Electric Utility Director

cc: Assistant Electric Utility Director
Electrical Engineer

APPROVED



THOMAS A. PETERSON
City Manager



recycled paper